



**OFFICE OF THE DISTRICT FIRE OFFICER,
HUBLICITY FIRE STATION HUBLI 580024**

C.N.46/ADV/CC/DFO/HUBLI CITY/2024

Date: 02/08/2024

To,
The Principal
Goutam Budha Education Society's ®
Shri Prakash English Medium Pre-Primary,
Primary & High School, R.M. Lohiya Nagar,
Gokul Road, Hubballi City Dharwad District

Sir,

Sub : Issue of '**Renewal Fire Safety Compliance Report**' with respect to Fire Prevention, Fire Fighting And Evacuation measures maintained/Required at Shri Prakash English Medium Pre-Primary, Primary & High School, R.M. Lohiya Nagar, Gokul Road, Hubballi City Dharwad District.

Ref : 1) This Office Compliance Certificate C.No.28/CC/DFO/Hubli City/2023
Date: 20-06-2023

2)Applicant request letter dated 26/07/2024

3) C.No.17/FSO/HFS/2024 Date-01-08-2024

>◇◇◇*@*◇◇◇<

With reference to the subject above cited, above, "Fire Safety Recommendation" was issued wide reference (1) to the premises of "Goutam Budha Education Society's ® Shri Prakash English Medium Pre-Primary, Primary & High School, R.M. Lohiya Nagar, Gokul Road, Hubballi City Dharwad District" with a condition to fulfil the recommendation and Compliance the same within 03 Months.

With reference cited (2) above the Mangement of the "Goutam Budha Education Society's ® Shri Prakash English Medium Pre-Primary, Primary & High School, R.M. Lohiya Nagar, Gokul Road, Hubballi City Dharwad District" had requested for the Renewal of Compliance Certificate from our Department. In this Regard Fire Station Officer Hubli City Fire Station was Inspected the Premises on 01-08-2024 And Submitted the report to issue of Compliance Certificate.

Under the Above circumstances & the report submitted by the Fire Station Officer Hubli City Fire Station, The Karnataka State Fire And Emergency Services Department is issuing the **'Renewal Fire Safety Compliance Report'** at Shri Prakash English Medium Pre-Primary, Primary & High School, R.M. Lohiya Nagar, Gokul Road, Hubballi City Dharwad District" subject to Proper maintenances of fire fighting installations in good working condation and to renew the Fire Safety Recommendation report for every Year.

"This Report is vaild for Five Years From the Date of Issue and is renewable without fail"

Note:40% of the available staff should be trained at R.A. Mundakur Fire Service Academy Bangalore so as to operte the Extinguishers in case of Emergency within the Period of three months.

Yours Faithfully


02/08/24

District Fire Officer
Karnataka Fire & Emergency Service
Fire Station, Hubli City,
HUBBALLI-580024

Copy:

01)Fire Station Officer Hubli City Fire Station.


PRINCIPAL
SHRI PRAKASH ENGLISH
MEDIUM SCHOOL
R. M. Lohiya Nagar, HUBLI.


PRESIDENT
SHRI GOUTAM BUDHA
EDUCATION SOCIETY